

UPITT

Test for Combustion Product Toxicity
For Obtaining MEA Certification from New York City

	LC 50 <u>grams</u>	LA 50 <u>(mm²)</u>
1" Snap-Trak® (Snap-Tex®) w/ Fiberglass Substrate and Guilford 701 fabric:	40.0	13,427

Interpretation:

Under New York City guidelines for obtaining MEA Certification, values of toxicity (as determined by this test alone) are allowed to be more than twice the value resulting from this test.